LEGEND FOR SPACES

⊐▭◁ ▭◁ PROPOSED LED LIGHT POLES

Lighting Notes:
1. All fixtures for parking and roadway shall be LEED.
2. Roadway and parking fixture mounting height shall be 30 ft. maximum.
3. All lighting shall be designed to be International Dark-Sky Association (IDA) Dark Sky Friendly.
4. All lighting fixtures will be Illuminating Engineering Society (IES) full cutoff to prevent spill-over of lighting off-site.
5. Lighting levels will not exceed Illuminating Engineering Society of North America (IESNA) guideline document RP-33-99 "Lighting for Exterior Environments" minimums.
6. Fixtures will have automatic controls with the capability of automatic shut for unused parking at night and at dawn and sunset, while still taking into account the safety of patrons and employees.

PARKING STRUCTURE

CASINO

HOTEL

DAY CARE/ HR OFFICE

ROUTE 208

MUSEUM VILLAGE MUSEUM VILLAGE RD

0   300'   600'
FEET

Live!
HOTEL & CASINO
NEW YORK

EXTERIOR LIGHTING PLAN