



Exhibit X.C.3. - Energy Efficient Equipment

Submit as Exhibit X.C.3. a description of Applicant's plans for ensuring use of Energy Star-rated equipment and high-efficiency HVAC equipment and appliances throughout the Gaming Facility complex.

The design of all of the mechanical systems will include high efficiency equipment that meets or exceeds the requirements of the ECCCNY 2010 and specifically the requirements of ASHRAE Standard 90.1-2007 as follows:

Air Conditioning Units	TABLE 6.8.1A
Heat Pump Units	TABLE 6.8.1B
Chillers	TABLE 6.8.1C
Unitary Air Conditioning Units	TABLE 6.8.1D
Boilers	TABLE 6.8.1F
Cooling Towers	TABLE 6.8.1G

All other appliances will be Energy Star rated.